

# CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality  
hereby attests that the product(s)

## Low Relaxation Stranded Steel Wire (Reinforcing Steel)

(Details as per the attached Scope of Certification)

manufactured by:

**AL RASHED STEEL PRODUCT MFG. CO.**  
**2nd Industrial Area, Dammam, KSA**

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

## ASTM A416 - 2015

Accordingly, DCLD hereby authorizes the above manufacturer  
to affix the DCL Product Conformity Mark on the above-mentioned product(s).



for / ENGR. AMIN AHMED AMIN  
Director, Dubai Central Laboratory Department  
Dubai Municipality



Certificate No: CL12020173  
Valid Until: 04/11/2019



Current Issue Date: 05/11/2018  
Original Issue Date: 05/11/2012

The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.  
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.



## DUBAI CENTRAL LABORATORY DEPARTMENT DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

### SCOPE OF CERTIFICATION

FOR CERTIFICATE NO. CL12020173

**Certificate Issued To:** Al Rashed Steel Product Mfg. Co.  
2nd Industrial Area, Dammam, K. S. A.

**Applicable Standard Specification:** ASTM A 416/A 416 M – 15 Standard Specification for Low Relaxation, Seven-Wire Steel Strand for Prestressed Concrete.

**Applicable Specific Rules:** RD-DP21-2131 (IC) "Specific Rules for Certification of Low Relaxation, Seven-Wire Steel Strand for Prestressed Concrete. (As per ASTM A 416/A 416 M –15) Through Factory Assessment".

S/N	Product Description	Nominal Diameter (mm)	Product Details
1	Steel Strand, Un-Coated Seven-Wire for Prestressed Concrete	9.53	Seven-Wire Low relaxation steel strand, <b>Grade 1860[270]</b> with nominal diameter 9.53mm, minimum Breaking Strength of 102 kN
2	Steel Strand, Un-Coated Seven-Wire for Prestressed Concrete	12.7	Seven-Wire Low relaxation steel strand, <b>Grade 1860[270]</b> with nominal diameter 12.7mm, minimum Breaking Strength of 184 kN
3	Steel Strand, Un-Coated Seven-Wire for Prestressed Concrete	15.2	Seven-Wire Low relaxation steel strand, <b>Grade 1860[270]</b> with nominal diameter 15.2 mm, minimum Breaking Strength of 261 kN
4	Steel Strand, Un-Coated Seven-Wire for Prestressed Concrete	15.7	Seven-Wire Low relaxation steel strand, <b>Grade 1860[270]</b> with nominal diameter 15.7 mm, minimum Breaking Strength of 279 kN

**NOTE1:** This document forms part of the Certificate of Product Conformity bearing the same certificate number.

**NOTE2:** The above product shall bear the DCL Conformity Mark (applied on each product or on the packaging).

**Original Issue Date** : 05<sup>th</sup> November 2012

**Current Issue Date** : 05<sup>th</sup> November 2018

**Valid Until** : 04<sup>th</sup> November 2019



ARIF HUSAIN AL MARZOOQI

Products Conformity Assessment Section Manager  
Dubai Central Laboratory Department